


## 900-FA Fire Alarm Input



Installation Instructions

900-8P (8 Zone,

Distribution-PTC)




The 900-FA Fire Alarm board can be installed on any one of the following power supply or option boards (refer to installation instructions):

Input (Fire Alarm)	Dry contacts required (Closed = no fire alarm) Connect control contacts between FA1 and FA2	
Output (Supervision)	30VDC, 1A resistive dry contact	
Board Input Power	Board requires 0.05A max. of power supply output current to operate	
Temperature Range	32°-120° F (0°- 49° C)	
Compliance	UL 294, ULC-S318, RoHS, & FCC Part 15	

WARNING


To avoid risk of electric shock, turn off AC power to power supply before installing or wiring 900-FA board. In the event a fire alarm is active, this board will remove power from the PS902 DC output and any 900-series option board output.



- If 900-FA was factory installed, go to step 2
- If installing to option board, go to 1a
- If installing to PS902 main board, go to 1b

## 1 a If installing to option board

Choose Option Board where 900-FA is to be Installed




Remove Jumper from Option Board

Install 900-FA to Option Board


Image: Comparison of the option Board

Customer Service			
1-877-671-7011	www.allegion.com		

## 1 b If installing to PS902 main board



**Remove Jumper**  $\overline{}$ 



© Allegion 2014

Printed in U.S.A.

Install 900-FA Here

Note: Complete power failure shall result in a fail safe operation. When connected to a fire alarm releasing control unit, total loss of power for the locking mechanisms shall be configured for a fail safe operation.

## 2 900-FA wiring

